

废水（总排口）自行监测结果

单位 mg/L (pH 除外)

项目 时间	PH	COD	NH ₃ -N					
2013-11-19	7.4	48	1					
标准限值		150	70					
达标情况		达标	达标					
备注	以连续排放的形式排入丹河							

废气自行监测结果

单位 mg/m³

项目 时间及点位		颗粒物	二氧化硫	氮氧化物	其它 (氟化物)
2013-11-19 锅炉 1 号	0:00		42	285	
	1:00		43	243	
	2:00		44	261	
	3:00		42	271	
	4:00		43	267	
	5:00		42	279	
	6:00		43	299	
	7:00		45	289	
	8:00		41	388	
	9:00		44	454	
	10:00		44	462	
	11:00		43	443	
	12:00		38	335	
	13:00		48	337	
	14:00		96	322	
	15:00		97	324	
	16:00		57	950	
	17:00		65	707	
	18:00		56	980	
	19:00		68	463	
20:00		53	562		
21:00		55	554		
22: 00		49	540		
23: 00		50	549		
标准限值			900	无	
达标情况			100%		
备注					

2013-11-19 锅炉 2 号	0:00		4.1	336	
	1:00		6.0	361	
	2:00		13.4	310	
	3:00		7.1	346	
	4:00		4.0	290	
	5:00		14.8	331	
	6:00		4.6	320	
	7:00		3.8	364	
	8:00		16	327	
	9:00		6.0	339	
	10:00		8.5	435	
	11:00		5.9	489	
	12:00		16	256	
	13:00		2.5	642	
	14:00		11	680	
	15:00		9.0	702	
	16:00		8.1	402	
	17:00		6.8	391	
	18:00		10.3	443	
	19:00		6.8	179	
	20:00		6.9	106	
	21: 00		6.3	49	
	22: 00		6.3	32	
	23: 00		7.4	92	
标准限值			900	无	
达标情况			100%		
备注					